

Ultraviolet Light Disinfection Data Sheet

UV has been used for disinfection since the mid-20th century, with beginnings even earlier when sunlight was investigated for bactericidal effects in the mid-19th century. It's used for drinking and wastewater treatment, air disinfection, the treatment of fruit and vegetable juices, as well as a myriad of home devices for disinfecting everything from toothbrushes to tablet computers. Within research facilities, UV has been an option when purchasing Biological Safety Cabinets for years, and can also be used within ductwork.

UV technology has advanced in recent years to become more reliable. Ballasts being used today are able to maintain the power output of UV bulbs for far longer than in the past. UV bulbs today have rated lifespans in the thousands of hours. This has allowed UV systems to become more viable for wide ranging use.



The use of UV has recently grown within the healthcare industry to provide disinfection of room surfaces in addition to existing cleaning methods. The use of ultraviolet light for surface disinfection within research facilities has started to increase as well due to its ease of use, short dosage times, and broad efficacy.



How Does UV Work?

Ultraviolet light exists within the spectrum of light between 10 and 400 nm. The germicidal range of UV is within the 100-280nm wavelengths, known as UV-C, with the peak wavelength for germicidal activity being 265 nm. This range of UV light is absorbed by the DNA and RNA of microorganisms, which causes changes in the DNA and RNA structure, rendering the microorganisms incapable of replicating. A cell that can't reproduce is considered dead; since it is unable to multiply to infectious numbers within a host. This is why UV disinfection is sometimes called ultraviolet germicidal irradiation (UVGI).

Our UV systems use low-pressure, mercury-arc germicidal lamps which are designed to produce the highest amounts of UV radiation - where 90% of energy is typically generated at 254nm. This radiation is very close to the peak of the germicidal effectiveness curve of 265nm, the most lethal wavelength to microorganisms.



What is UV Effective Against?

UV has been proven effective against a broad spectrum of microorganisms. Viruses contain RNA or DNA and are thus susceptible to irradiation. Bacteria and fungi both contain DNA and are similarly vulnerable to UV light. Spores are also susceptible to UV. With the longstanding use of UV for disinfection, there is a plethora of information regarding dosages necessary to inactivate different microorganisms. Bacteria are generally easier to inactivate than viruses, with fungi and spores being even harder to inactivate with UV. **Please see Appendix 2 for a list of microorganisms which UV-C is effective against.**

Safety

As UV-C provides radiation, it is not safe to be in the room while UV-C disinfection is taking place. UV-C is classified as “reasonably anticipated to be a human carcinogen” by the National Toxicology Program. It presents a hazard to skin and eyes, so direct exposure to UV-C is always to be avoided. UV-C is blocked by a number of materials, including glass (but not quartz glass) and most clear plastics, so it is possible to safely observe a UV-C system if you are looking through a window. UV-C provides residue free disinfection, so there is no concern over dangerous residues that need to be wiped down or neutralized after the disinfection occurs. The process is environmentally friendly in that there are no dangerous or toxic chemicals that require specialized storage or handling. Since no chemicals are added to the air/water there are no process byproducts to be concerned with. The UV bulbs do not require special handling or disposal either, making the system a green alternative to chemical disinfectants.

Benefits

While there are definite limitations to UV-C disinfection technologies, there are many benefits as well. Disinfection times are fast, with a typical disinfection cycle lasting about 15 minutes. This allows for extremely fast turnover times for rooms or other spaces being disinfected. Due to its simplicity, UV-C disinfection is extremely easy to understand. All surfaces within a certain distance will observe an assured level of disinfection in a certain amount of time as long as the light is not blocked from shining on that surface. It becomes very easy to plan the use of a UV-C disinfection system when the parameters and limitations are easily established and understood.

There is no need to establish air flow patterns with UV-C as you would with a fogging system. Nor is there a need to isolate rooms from HVAC systems or seal doors. This, along with the lack of chemical mixture, makes the preparation time quick to setup and start a UV-C disinfection cycle.

The cost to run UV systems is very low, as systems are powered by regular wall outlets. With that, a typical UV-C treatment costs under 2 cents. UV systems also require little maintenance and upkeep due to their simplistic nature. UV bulbs last thousands of hours at their peak output, limiting the need for routine consumable change out and maintenance.

Drawbacks

While UV is effective at inactivating a wide range of microorganisms, there are limitations for its use. As it involves light waves, UV operates in a “line of sight” fashion, only irradiating surfaces within its sightlines. Surfaces can be blocked from the light if objects are in the way, much like a beach umbrella offering protection from the sun. These areas that become blocked from the UV light are commonly referred to as shadow areas. Surfaces in these shadow areas do not receive adequate disinfection as UV light does not have the ability to reflect well off surfaces. Shadow areas are typically dealt with by moving the UV light source to a second position to accommodate disinfection of the surfaces blocked from UV disinfection the first time.

Distance also plays a factor into the efficacy of UV light. The strength of the UV-C light decreases the further away it gets from the light source, following the inverse square law. This means that at twice the distance, the UV-C will have $\frac{1}{4}$ of its power that was present at the original reference point. This relationship limits how far a single source of UV light is effective before it is too weak to provide adequate disinfection. Most systems deal with this by quantifying their UV-C output at a given distance, and using that distance to generate treatment times. Sensors are available which can measure the UV-C output of the UV systems at any location, such that adequate treatment times can be interpreted for that specific location.

UV light does not penetrate well into organic materials, so for best results UV-C should be used after a standard cleaning of the room to remove any organic materials from surfaces.

Applications

UV light can safely be used for a variety of disinfection applications. Systems are available to disinfect rooms and high touch areas, ambulances and other emergency service vehicles, ductwork, tools equipment inside a disinfection chamber, continuous UV-C passthrough conveyors, and many other applications. It has long been available for Biological Safety Cabinet disinfection and home water treatment as well. It provides a chemical free method of disinfecting soundproofing materials that are traditionally chemically incompatible.

Appendix 1 – Historical Use of UV Light for Disinfection

For the past 100 years science has recognized the bactericide effects of the ultraviolet area of the electromagnetic spectrum. Below are some key contributions over the years:

- 1855 Arloing and Daclaux demonstrated sunlight killed *Bacillus anthracis* and *Tyrophthrix scaber*
- 1877 Downes and Blunt reported bacteria were inactivated by sunlight – violet blue spectrum most effective
- 1889 Widmark confirmed UV rays from arc lamps were responsible for inactivation
- 1892 Geisler used a prism and heliostat to show sunlight and electric arc lamps are lethal to *Bacillus Typhosus*
- 1903 Banard and Morgan determined UV spectrum 226-328 nm is biocidal
- 1932 Ehris and Noethling isolated biocidal spectrum to 253.7 nm
- 1957 Riley proves effectiveness for Tb control
- 1994 CDC acknowledges UV effectiveness for Tb control
- 1999 WHO recommends UVGI for Tb control

Appendix 2 – Ultraviolet Light Exposure Dosage

The degree of inactivation by ultraviolet radiation is directly related to the UV dose applied. The UV dose is the product of UV intensity [I] (expressed as energy per unit surface area) and exposure time [T].

Therefore: DOSE = I x T

This dose, sometimes referred to as fluence, is commonly expressed as millijoule per square centimeter (mJ/cm²). The units "J/m²" are used in most parts of the world except for North America, where "mJ/cm²" are used.

The reduction of micro-organisms is classified using a logarithmic scale. A single log reduction is a 90% reduction of organisms. A two log reduction is a 99% reduction of organisms, followed by a three log reduction (99.9%), etc. The UV-C exposure dosage needed for each level of reduction is shown in the table along with the published reference where the data came from.

	UV Dose (mJ/cm ²) Needed For a Given Log Reduction						Reference
	1	2	3	4	5	6	
Spore							
<i>Bacillus anthracis</i> spores - Anthrax spores	24.32	46.2					Light Sources Inc. 2014
<i>Bacillus magaterium</i> sp. (spores)	2.73	5.2					Light Sources Inc. 2014
<i>Bacillus subtilis</i> ATCC6633	24	35	47	79			Mamane-Gravetz and Linden 2004
<i>Bacillus subtilis</i> WN626	0.4	0.9	1.3	2			Marshall et al., 2003
<i>Bacillus subtilis</i> spores	11.6	22.0					Light Sources Inc. 2014
Bacterium							
<i>Aeromonas salmonicida</i>	1.5	2.7	3.1	5.9			Liltved and Landfald 1996
<i>Aeromonas hydrophila</i> ATCC7966	1.1	2.6	3.9	5	6.7	8.6	Wilson et al. 1992
<i>Bacillus anthracis</i> - Anthrax	4.52	8.7					Light Sources Inc. 2014
<i>Bacillus magaterium</i> sp. (veg.)	1.3	2.5					Light Sources Inc. 2014
<i>Bacillus paratyphus</i>	3.2	6.1					Light Sources Inc. 2014
<i>Bacillus subtilis</i>	5.8	11.0					Light Sources Inc. 2014
<i>Campylobacter jejuni</i> ATCC 43429	1.6	3.4	4	4.6	5.9		Wilson et al. 1992
<i>Citrobacter diversus</i>	5	7	9	11.5	13		Giese and Darby 2000
<i>Citrobacter freundii</i>	5	9	13				Giese and Darby 2000
<i>Clostridium tetani</i>	13.0	22.0					Light Sources Inc. 2014
<i>Corynebacterium diphtheriae</i>	3.37	6.51					Light Sources Inc. 2014

	UV Dose (mJ/cm ²) Needed For a Given Log Reduction						Reference
	Log Reduction						
	1	2	3	4	5	6	
<i>Ebertelia typhosa</i>	2.14	4.1					Light Sources Inc. 2014V
<i>Escherichia coli</i> O157:H7 CCUG 29193	3.5	4.7	5.5	7			Sommer et al. 2000
<i>Escherichia coli</i> O157:H7 CCUG 29197	2.5	3	4.6	5	5.5		Sommer et al. 2000
<i>Escherichia coli</i> O157:H7 CCUG 29199	0.4	0.7	1	1.1	1.3	1.4	Sommer et al. 2000
<i>Escherichia coli</i> O157:H7 ATCC 43894	1.5	2.8	4.1	5.6	6.8		Wilson et al. 1992
<i>Escherichia coli</i>	3.0	6.6					Light Sources Inc. 2014
<i>Escherichia coli</i> ATCC 11229	7	8	9	11	12		Hoyer 1998
<i>Escherichia coli</i> ATCC 11303	4	6	9	10	13	15	Wu et al. 2005
<i>Escherichia coli</i> ATCC 25922	6	6.5	7	8	9	10	Sommer et al. 1998
<i>Escherichia coli</i> K-12 IFO3301	2.2	4.4	6.7	8.9	11.0		Oguma et al. 2004
<i>Escherichia coli</i> O157:H7	<2	<2	2.5	4	8	17	Yaun et al. 2003
<i>Halobacterium elongate</i> ATCC33173	0.4	0.7	1				Martin et al. 2000
<i>Halobacterium salinarum</i> ATCC43214	12	15	17.5	20			Martin et al. 2000
<i>Klebsiella pneumoniae</i>	12	15	17.5	20			Giese and Darby 2000
<i>Klebsiella terrigena</i> ATCC33257	4.6	6.7	8.9	11			Wilson et al. 1992
<i>Legionella pneumophila</i> ATCC33152	1.9	3.8	5.8	7.7	9.6		Oguma et al. 2004
<i>Legionella pneumophila</i> ATCC 43660	3.1	5	6.9	9.4			Wilson et al. 1992
<i>Legionella pneumophila</i> ATCC33152	1.6	3.2	4.8	6.4	8.0		Oguma et al. 2004
<i>Leptospira canicola</i> - Infectious Jaundice	3.15	6.0					Light Sources Inc. 2014
<i>Micrococcus candidus</i>	6.05	12.3					Light Sources Inc. 2014
<i>Micrococcus sphaeroides</i>	1.0	15.4					Light Sources Inc. 2014
<i>Mycobacterium tuberculosis</i>	6.2	10.0					Light Sources Inc. 2014
<i>Neisseria catarrhalis</i>	4.4	8.5					Light Sources Inc. 2014
<i>Phytomonas tumefaciens</i>	4.4	8.0					Light Sources Inc. 2014
<i>Proteus vulgaris</i>	3.0	6.6					Light Sources Inc. 2014
<i>Pseudomonas stutzeri</i>	100	150	195	230			Joux et al. 1999
<i>Pseudomonas aeruginosa</i>	5.5	10.5					Light Sources Inc. 2014
<i>Pseudomonas fluorescens</i>	3.5	6.6					Light Sources Inc. 2014
<i>Salmonella paratyphi</i> - Enteric fever	3.2	6.1					Light Sources Inc. 2014
<i>Salmonella anatum</i> (from human feces)	7.5	12	15				Tosa and Hirata 1998
<i>Salmonella derby</i> (from human feces)	3.5	7.5					Tosa and Hirata 1998
<i>Salmonella enteritidis</i> (from human feces)	5	7	9	10			Tosa and Hirata 1998
<i>Salmonella infantis</i> (from human feces)	2	4	6				Tosa and Hirata 1998
<i>Salmonella spp.</i>	<2	2	3.5	7	14	29	Yaun et al. 2003
<i>Salmonella typhi</i> ATCC 19430	1.8	4.8	6.4	8.2			Wilson et al. 1992
<i>Salmonella typhi</i> ATCC 6539	2.7	4.1	5.5	7.1	8.5		Chang et al. 1985
<i>Salmonella typhimurium</i> (from human feces)	2	3.5	5	9			Tosa and Hirata 1998
<i>Salmonella typhimurium</i>	50	100	175	210	250		Joux et al. 1999
<i>Salmonella enteritidis</i>	4.0	7.6					Light Sources Inc. 2014
<i>Salmonella typhimurium</i>	8.0	15.2					Light Sources Inc. 2014
<i>Salmonella typhosa</i> - Typhoid fever	2.15	4.1					Light Sources Inc. 2014
<i>Sarcina lutea</i>	19.7	26.4					Light Sources Inc. 2014
<i>Serratia marcescens</i>	2.42	6.16					Light Sources Inc. 2014
<i>Shigella dysenteriae</i> ATCC29027	0.5	1.2	2	3	4	5.1	Wilson et al. 1992
<i>Shigella dysenteriae</i> - Dysentery	2.2	4.2					Light Sources Inc. 2014
<i>Shigella flexneri</i> - Dysentery	1.7	3.4					Light Sources Inc. 2014
<i>Shigella paradysenteriae</i>	1.68	3.4					Light Sources Inc. 2014
<i>Shigella sonnei</i> ATCC9290	3.2	4.9	6.5	8.2			Chang et al. 1985
<i>Spirillum rubrum</i>	4.4	6.16					Light Sources Inc. 2014

	UV Dose (mJ/cm ²) Needed For a Given Log Reduction						Reference
	Log Reduction						
	1	2	3	4	5	6	
<i>Staphylococcus aureus</i> ATCC25923	3.9	5.4	6.5	10.4			Chang et al. 1985
<i>Staphylococcus albus</i>	1.84	5.72					Light Sources Inc. 2014
<i>Staphylococcus aureus</i>	2.6	6.6					Light Sources Inc. 2014
<i>Staphylococcus hemolyticus</i>	2.16	5.5					Light Sources Inc. 2014
<i>Staphylococcus lactis</i>	6.15	8.8					Light Sources Inc. 2014
<i>Streptococcus faecalis</i> (secondary effluent)	5.5	6.5	8	9	12		Harris et al. 1987
<i>Streptococcus faecalis</i> ATCC29212	6.6	8.8	9.9	11.2			Chang et al. 1985
<i>Streptococcus viridans</i>	2.0	3.8					Light Sources Inc. 2014
<i>Vibrio anguillarum</i>	0.5	1.2	1.5	2			Liltved and Landfald 1996
<i>Vibrio cholerae</i> ATCC25872	0.8	1.4	2.2	2.9	3.6	4.3	Wilson et al. 1992
Vibrio comma - Cholera	3.375	6.5					Light Sources Inc. 2014
<i>Vibrio natriegens</i>	37.5	75	100	130	150		Joux et al. 1999
<i>Yersinia enterocolitica</i> ATCC27729	1.7	2.8	3.7	4.6			Wilson et al. 1992
<i>Yersinia ruckeri</i>	1	2	3	5			Liltved and Landfald 1996
Yeasts							
Brewers yeast	3.3	6.6					Light Sources Inc. 2014
Common yeast cake	6.0	13.2					Light Sources Inc. 2014
<i>Saccharomyces carevisiae</i>	6.0	13.2					Light Sources Inc. 2014
<i>Saccharomyces ellipsoideus</i>	6.0	13.2					Light Sources Inc. 2014
<i>Saccharomyces</i> spores	8.0	17.6					Light Sources Inc. 2014
Molds							
<i>Aspergillus flavus</i>	60.0	99.0					Light Sources Inc. 2014
<i>Aspergillus glaucus</i>	44.0	88.0					Light Sources Inc. 2014
<i>Aspergillus niger</i>	132.0	330.0					Light Sources Inc. 2014
<i>Mucor racemosus</i> A	17.0	35.2					Light Sources Inc. 2014
<i>Mucor racemosus</i> B	17.0	35.2					Light Sources Inc. 2014
<i>Oospora lactis</i>	5.0	11.0					Light Sources Inc. 2014
<i>Penicillium digitatum</i>	44.0	88.0					Light Sources Inc. 2014
<i>Penicillium expansum</i>	13.0	22.0					Light Sources Inc. 2014
<i>Penicillium roqueforti</i>	13.0	26.4					Light Sources Inc. 2014
<i>Rhizopus nigricans</i>	111.0	220.0					Light Sources Inc. 2014
Protozoan							
<i>Chlorella Vulgaris</i>	13.0	22.0					Light Sources Inc. 2014
<i>Cryptosporidium hominis</i>	3	5.8					Johnson et al. 2005
<i>Cryptosporidium parvum</i>	2.4	<5	5.2	9.5			Craik et al. 2001
<i>Cryptosporidium parvum</i> , oocysts, tissue culture assay	1.3	2.3	3.2				Shin et al. 2000
<i>Encephalitozoon cuniculi</i> , microsporidia	4	9	13				Marshall et al. 2003
<i>Encephalitozoon hellem</i> , microsporidia	8	12	18				Marshall et al. 2003
<i>Encephalitozoon intestinalis</i> , microsporidia	3	5	6				Marshall et al. 2003
<i>G. muris</i> , cysts	<5	<5	5				Amoah et al. 2005
<i>G. muris</i> , cysts, mouse infectivity assay	<2	<6	10 + tailing				Craik et al. 2000
<i>Giardia lamblia</i>	<10	~10	<20				Campbell et al. 2002
<i>Giardia muris</i>	<1.9	<1.9	~2	~2.3			Hayes et al. 2003
<i>Nematode Eggs</i>	45.0	92.0					Light Sources Inc. 2014
<i>Paramecium</i>	11.0	20.0					Light Sources Inc. 2014

The following table shows the required UV-C exposure dosages necessary for various log reductions of viruses.

UV Dose (mJ/cm ²) Needed For a Given Log Reduction								
Log Reduction								
Virus	Host	1	2	3	4	5	6	
Adenovirus type 15	A549 cell line (ATCC CCL-185)	40	80	122	165	210		Thompson et al. 2003
Adenovirus type 2	A549 cell line	20	45	80	110			Shin et al. 2005
Adenovirus type 2	Human lung cell line	35	55	75	100			Ballester and Malley 2004
Adenovirus type 2	PLC / PRF / 5 cell line	40	78	119	160	195	235	Gerba et al. 2002
Adenovirus type 40	PLC / PRF / 5 cell line	55	105	155				ston-Enriquez et al. 2003
Adenovirus type 41	PLC / PRF / 5 cell line	23.6	ND	ND	111.8			Meng and Gerba 1996
B40-8 (Phage)	B. Fragilis	11	17	23	29	35	41	Sommer et al. 2001
Bacteriophage - E. Coli	N/A	2.6	6.6					Light Sources Inc. 2014
Calicivirus canine	MDCK cell line	7	15	22	30	36		Husman et al. 2004
Calicivirus feline	CRFK cell line	5	15	23	30	39		ston-Enriquez et al. 2003
Coxsackievirus B3	BGM cell line	8	16	24.5	32.5			Gerba et al. 2002
Coxsackievirus B5	Buffalo Green Monkey cell line	6.9	13.7	20.6				Battigelli et al. 1993
Coxsackievirus B5	BGM cell line	9.5	18	27	36			Gerba et al. 2002
Echovirus I	BGM cell line	8	16.5	25	33			Gerba et al. 2002
Echovirus II	BGM cell line	7	14	20.5	28			Gerba et al. 2002
Hepatitis A	HAV/HFS/GBM	5.5	9.8	15	21			Wiedenmann et al. 1993
Hepatitis A HM175	FRhK-4 cell	5.1	13.7	22	29.6			Wilson et al. 1992
Hepatitis A HM175	FRhK-4 cell	4.1	8.2	12.3	16.4			Battigelli et al. 1993
Infectious Hepatitis	N/A	5.8	8.0					Light Sources Inc. 2014
Influenza	N/A	3.4	6.6					Light Sources Inc. 2014
MS2 (Phage)	Salmonella typhimurium WG49	16.3	35	57	83	114	152	Nieuwstad and Havelaar
MS2 (Phage)	E. coli ATCC 15597	20	42	70	98	133		Lazarova and Savoye 2004
MS2 (Phage)	E. coli HS(pFamp)R		45	75	100	125	155	Thompson et al. 2003
MS2 ATCC 15977-B1 (Phage)	E. coli ATCC 15977-B1	15.9	34	52	71	90	109	Wilson et al. 1992
MS2 DSM 5694 (Phage)	E. coli NCIB 9481	4	16	38	68	110		Wiedenmann et al. 1993
MS2 NCIMB 10108 (Phage)	Salmonella typhimurium WG49	12.1	30.1					Tree et al. 1997
PHI X 174 (Phage)	E. coli C3000	2.1	4.2	6.4	8.5	10.6	12.7	Battigelli et al. 1993
PHI X 174 (Phage)	E. coli WG 5	3	5	7.5	10	12.5	15	Sommer et al. 2001
Poliovirus - Poliomyelitis	N/A	3.15	6.6					Light Sources Inc. 2014
Poliovirus 1	BGM cell line	5	11	18	27			Tree et al. 2005
Poliovirus 1	CaCo2 cell-line (ATCC HTB37)	7	17	28	37			Thompson et al. 2003

UV Dose (mJ/cm ²) Needed For a Given Log Reduction								
Log Reduction								
Virus	Host	1	2	3	4	5	6	
Poliovirus Type Mahoney	Monkey kidney cell line Vero	3	7	14	40			Sommer et al. 1989
Poliovirus Type 1 LSc2ab ()	MA104 cell	5.6	11	16.5	21.5			Chang et al. 1985
Poliovirus Type 1 LSc2ab	BGM cell	5.7	11	17.6	23.3	32	41	Wilson et al. 1992
PRD-1 (Phage)	S. typhimurium Lt2	9.9	17.2	23.5	30.1			Meng and Gerba 1996
Reovirus Type 1 Lang strain	N/A	16	36					Harris et al. 1987
Reovirus-3	Mouse L-60	11.2	22.4					Rauth 1965
Rotavirus	MA104 cells	20	80	140	200			Caballero et al. 2004
Rotavirus SA-11	MA-104 cell line	9.1	19	26	36	48		Wilson et al. 1992



References:

- Amoah, K., Craik, S., Smith, D.W. and Belosevic, M. 2005. Inactivation of *Cryptosporidium* oocysts and *Giardia* cysts by ultraviolet light in the presence of natural particulate matter, *AQUA, J. Wat. Supply* 54(3): 165-178.
- Ballester, N.A. and Malley, J.P. 2004. Sequential disinfection of adenovirus type 2 with UV-chlorinechloramine, *J. Amer. Wat. Works Assoc.*, 96(10): 97-102.
- Batch, L.F., Schulz, C.R. and Linden, K.G. 2004. Evaluating water quality effects on UV disinfection of MS2 coliphage, *J. Amer. Wat. Works Assoc.*, 96(7): 75-87.
- Battigelli, D.A., Sobsey, M.D. and Lobe, D.C. 1993. The inactivation of Hepatitis A virus and other model viruses by UV irradiation, *Wat. Sci. Tech.*, 27(3-4): 339-342.
- Belosevic, M., Craik, S.A., Stafford, J.L. Neumann, N.E., Kruihof, J. and Smith, D.W. 2001. Studies on the resistance/reaction of *Giardia muris* cysts and *C. parvum* oocysts exposed to medium-pressure ultraviolet radiation, *FEMS Microbiol. Lett.*, 204(1): 197-204.
- Bolton J.R. and Linden, K.G. 2003. Standardization of methods for fluence (UV Dose) determination in benchscale UV experiments. *J. Environ. Eng.* 129(3): 209-216.
- Bukhari, Z., Abrams, F. and LeChevallier, M. 2004. Using ultraviolet light for disinfection of finished water, *Water Sci. Tech.*, 50(1): 173-178.
- Caballero, S., Abad, F.X., Loisy, F., LeGuyader, F.S., Cohen, J., Pinto, R.M. and Bosch, A. 2004. Rotavirus virus-like particles as surrogates in environmental persistence and inactivation studies, *Appl. Environ. Microbiol.* 70(7): 3904-3909.
- Campbell, A.T. and Wallis, P. 2002. The effect of UV irradiation on human-derived *Giardia lamblia* cysts, *Wat. Res.*, 36(4): 963-969.
- Carlson, D.A., Seabloom, R.W., DeWalle, F.B., Wetzler, T.F., Engeset, J., Butler, R., Wangsuphachart, S. and Wang, S. 1985. Ultraviolet disinfection of water for small water supplies. US EPA Report No. EPA/600/S2-85/092.
- Cass AL, Kelly JW, Probst JC, Addy CL, McKeown RE. Identification of device-associated infections utilizing administrative data. *American Journal of Infection Control.* 2013; Published online 17 June 2013.
- Chang, J.C.H., Osoff, S.F., Lobe, D.C., Dorfman, M.H., Dumais, C.M., Qualls, R.G. and Johnson, J.D. 1985. UV inactivation of pathogenic and indicator microorganisms, *Appl. Environ. Microbiol.*, 49(6): 1361-1365.
- Clancy, J.L., Bukhari, Z., Hargy, T.M., Bolton, J.R., Dussert, B.W. and Marshall, M.M. 2000. Using UV to inactivate *Cryptosporidium* – Even extremely low dosages of ultraviolet light can be highly effective for inactivating *Cryptosporidium* oocysts, *J. Amer. Wat. Works Assoc.*, 92(9): 97-104.
- Clancy, J.L., Marshall, M.M., Hargy, T.M. and Korich, D.G. 2004. Susceptibility of five strains of *Cryptosporidium parvum* oocysts to UV light, *J. Amer. Wat. Works Assoc.*, 96(3), 84-93.
- Craik, S.A., Finch, G.R., Bolton, J.R. and Belosevic, M. 2000. Inactivation of *Giardia muris* cysts using medium-pressure ultraviolet radiation in filtered water, *Wat. Res.*, 34(18): 4325-4332.
- Craik, S.A., Weldon, D., Finch, G.R., Bolton, J.R. and Belosevic, M. 2001. Inactivation of *Cryptosporidium parvum* oocysts using medium- and low-pressure ultraviolet radiation, *Wat. Res.*, 35(6): 1387-1398.
- Faires MC, Pearl DL, Berke O, Reid-Smith RJ, Weese JS. The identification and epidemiology of methicillin-resistant *Staphylococcus aureus* and *Clostridium difficile* in patient rooms and the ward environment. *BMC Infectious Diseases* 2013, 13:342
- Gerba, C.P., Gramos, D.M. and Nwachuku, N. 2002. Comparative inactivation of enteroviruses and adenovirus 2 by UV light, *Appl. Environ. Microbiol.*, 68(10): 5167-5169.
- Giese, N. and Darby, J. 2000. Sensitivity of microorganisms to different wavelengths of UV light: implications on modeling of medium pressure UV systems, *Wat. Res.*, 34(16): 4007-4013.
- Grohskopf LA, Sinkowitz-Cochran RL, Garrett Dom et al. A national point-prevalence survey of pediatric intensive care unit-acquired infections in the United States. *Journal of Pediatrics.* 2002; 140, 432-438.
- Harris, G.D., Adams, V.D., Sorensen, D.L. and Curtis, M.S. 1987. Ultraviolet inactivation of selected bacteria and viruses with photoreactivation of the bacteria, *Wat. Res.*, 21(6): 687-692.
- Hayes, S.L., Rice, E.W., Ware, M.W. and Schaefer III, F.W. 2003. Low pressure ultraviolet studies for inactivation of *Giardia muris* cysts, *J. Appl. Microbiol.*, 94(1): 54-59.
- Hijnen, W.A.M., Beerendonk, E.F. and Medema, G.J. 2006. Inactivation credit of UV radiation for viruses, bacteria and protozoan (oo)cysts in water; a review, *Wat. Res.*, 40(1): 3-22.
- Hoyer, O. 1998. Testing performance and monitoring of UV systems for drinking water disinfection, *Wat. Supply*, 16(1-2): 424-429.
- Huffman, D.E., Gennaccaro, A., Rose, J.B. and Dussert, B.W. 2002. Low- and medium-pressure UV inactivation of microsporidia *Encephalitozoon intestinalis*, *Wat. Res.*, 36(12): 3161-3164.
- Husman, A.M.D., Bijkerk, P., Lodder, W., Van den Berg, H., Pribil, W., Cabaj, A., Gehringer, P., Sommer, R. and Duizer, E. 2004. Calicivirus inactivation by nonionizing 253.7-nanometer-wavelength (UV) and ionizing (Gamma) radiation, *Appl. Environ. Microbiol.*, 70(9): 5089-5093.
- Infection Control Breaches in the Operating Room. *Infection Control Today.* 2013.
- Johnson, A.M., Linden, K., Ciociola, K.M., De Leon, R., Widmer, G. and Rochelle, P.A. 2005. UV inactivation of *Cryptosporidium hominis* as measured in cell culture, *Appl. Environ. Microbiol.*, 71(5): 2800-2802.
- Joux, F., Jeffrey, W.H., Lebaron, P. and Mitchell, D. L. 1999. Marine bacterial isolates display diverse responses to UV-B radiation, *Appl. Environ. Microbiol.*, 65(9): 3820-3827.
- Karanis, P., Maier, W.A., Seitz, H.M. and Schoenen, D. 1992. UV sensitivity of protozoan parasites, *Aqua*, 41:95-100.
- Lazarova, V. and Savoye, P. 2004. Technical and sanitary aspect of wastewater disinfection by ultraviolet irradiation for landscape irrigation, *Wat. Sci. Technol.*, 50(2): 203-209.
- Light Sources Inc and American Ultraviolet Company. UV Irradiation Dosage Table. Accessed from <http://www.americanairandwater.com/uv-facts/uv-dosage.htm>. Accessed on 3-26-2014
- Liltved, H. and Landfald, B. 1996. Influence of liquid holding recovery and photoreactivation on survival of ultraviolet-irradiated fish pathogenic bacteria, *Wat. Res.*, 30(5): 1109-1114.
- Linden, K.G., Batch, L. and Schulz, C. 2002a. UV disinfection of filtered water supplies: water quality impacts on MS2 dose-response curves, *Proceedings Amer. Wat. Works Assoc. Annu. Conf.*, Amer. Wat. Works Assoc., Denver, CO.
- Linden, K.G., Shin, G.-A., Faubert, G., Cairns, W. and Sobsey, M.D. 2002b. UV disinfection of *Giardia lamblia* cysts in water, *Environ. Sci. Technol.*, 36(11): 2519-2522.
- Lucado, J., Paez, K., Andrews, R., Steiner, C. Adult Hospital Stays with Infections Due to Medical Care, 2007. HCUP Statistical Brief #94. August 2010. Agency for Healthcare Research and Quality, Rockville, MD.
- Mamane-Gravetz, H. and Linden, K.G. 2004. UV disinfection of indigenous aerobic spores: Implications for UV reactor validation in unfiltered waters, *Wat. Res.*, 38(12): 2898-2906.
- Marshall, M.M., Hayes, S., Moffett, J., Sterling, C.R. and Nicholson, W.L. 2003. Comparison of UV inactivation of three *Encephalitozoon* species with that of spores of two DNA repair-deficient *Bacillus subtilis* biosimetry strains, *Appl. Environ. Microbiol.*, 69(1): 683-685.
- Martin, E.L., Reinhardt, R.L., Baum, L.L., Becker, M.R., Shaffer, J.J. and Kokjohn, T.A. 2000. The effects of ultraviolet radiation on the moderate halophile *Halomonas elongata* and the extreme halophile *Halobacterium salinarum*, *Can. J. Microbiol.*, 46(2): 180-187.
- Maya, C., Beltran, N., Jimenez, B. and Bonilla, P. 2003. Evaluation of the UV disinfection process in bacteria and amphizoic amoebae inactivation, *Wat. Sci. Technol.: Wat. Supply*, 3(4): 285-291.
- Meng, Q.S. and Gerba, C.P. 1996. Comparative inactivation of enteric adenoviruses, poliovirus and coliphages by ultraviolet irradiation, *Wat. Res.*, 30(11): 2665-2668.

- Mofidi, A.A., Meyer, E.A., Wallis, P.M., Chou, C.I., Meyer, B.P., Ramalingam, S. and Coffey, B.M. 2002. The effect of UV light on the inactivation of *Giardia lamblia* and *Giardia muriscysts* as determined by animal infectivity assay, *Wat. Res.*, 36(8): 2098-2108.
- Morita, S., Namikoshi, A., Hirata, T., Oguma, K., Katayama, H., Ohgaki, S., Motoyama, N. and Fujiwara, M. 2002. Efficacy of UV irradiation in inactivating *C. parvum* oocysts, *Appl. Environ. Microbiol.*, 68(11):5387-5393.
- Nieuwstad, T.J. and Havelaar, A.H. 1994. The kinetics of batch ultraviolet inactivation of bacteriophage MS2 and microbiological calibration of an ultraviolet pilot plant, *J. Environ. Sci. Health*, A29(9): 1993-2007.
- Oguma, K., Katayama, H. and Ohgaki, S. 2002. Photoreactivation of *E. coli* after low- or medium- pressure UV disinfection determined by an endonuclease sensitive site assay, *Appl. Environ. Microbiol.*, 68(12), 6029-6035.
- Oguma, K., Katayama, H. and Ohgaki, S. 2004. Photoreactivation of *Legionella pneumophila* after inactivation by low- or medium-pressure ultraviolet lamp, *Wat. Res.*, 38(11): 2757-2763.
- Oppenheimer, J.A., Hoagland, J.E., Laine, J.-M., Jacangelo, J.G. and Bhamrah, A. 1993. Microbial inactivation and characterization of toxicity and by-products occurring in reclaimed wastewater disinfected with UV radiation, *Conf. on Planning, Design and Operation of Effluent Disinfection Systems*, Whippany, NJ, May 23-25, 1993,
- Pyrek, K. Pathogen Persistence, Transmission and Cross-Contamination Prevention. VIRGO Publishing. Aug 2012.
- Wat. Environ. Fed., Alexandria, VA Otaki, M., Okuda, A., Tajima, K., Iwasaki, T., Kinoshita, S. and Ohgaki, S. 2003. Inactivation differences of microorganisms by low pressure UV and pulsed xenon lamps, *Wat. Sci. Technol.*, 47(3): 185-190.
- Rauth, A.M. 1965. The physical state of viral nucleic acid and the sensitivity of viruses to ultraviolet light, *Biophys. J.*, 5: 257-273.
- Rice, E.W. and Hoff, J.C. 1981. Inactivation of *Giardia lamblia* cysts by ultraviolet irradiation, *Appl. Environ. Microbiol.*, 42(3): 546-547.
- Shin, G.-A., Linden, K.G. and Sobsey, M.D. 2000. Comparative inactivation of *Cryptosporidium parvum* oocysts and coliphage MS2 by monochromatic UV radiation, *Proceedings of Disinfection 2000: Disinfection of Wastes in the New Millennium*, New Orleans, Water Environment Federation, Alexandria, VA.
- Shin, G.-A., Linden, K.G., Arrowood, M.J. and Sobsey, M.D. 2001. Low-pressure UV inactivation and DNA repair potential of *C. parvum* oocysts, *Appl. Environ. Microbiol.*, 67(7): 3029-3032.
- Shin, G.A., Linden, K.G. and Sobsey, M.D. 2005. Low pressure ultraviolet inactivation of pathogenic enteric viruses and bacteriophages, *J. Environ. Engr. Sci.*, 4: S7-S11.
- Sommer, R., Weber, G., Cabaj, A., Wekerle, J., Keck, G., and Schaubberger, G. 1989. UV inactivation of micro-organisms in water. *Zbl. Hyg.* 189: 214-224.
- Sommer, R., Haider, T., Cabaj, A., Pribil, W. and Lhotsky, M. 1998. Time dose reciprocity in UV disinfection of water, *Water Sci. Technol.*, 38(12): 145-150.
- Sommer, R., Cabaj, A., Sandu, T. and Lhotsky, M. 1999. Measurement of UV radiation using suspensions of microorganisms, *J. Photochem. Photobiol.*, 53(1-3): 1-5.
- Sommer, R., Lhotsky, M., Haider, T. and Cabaj, A. 2000. UV inactivation, liquid-holding recovery, and photoreactivation of *E. coli* O157 and other pathogenic *E. coli* strains in water, *J. Food Protection*, 63(8): 1015-1020.
- Sommer, R., Pribil, W., Appelt, S., Gehringer, P., Eschweiler, H., Leth, H., Cabaj, A. and Haider, T. 2001. Inactivation of bacteriophages in water by means of non-ionizing (UV-253.7 nm) and ionizing (gamma) radiation: A comparative approach, *Wat. Res.*, 35(13): 3109- 3116.
- Srinivasan MD, Arjun, American Recovery and Reinvestment Act Epidemiology and Laboratory Capacity (ELC) for Infectious Disease Program Healthcare-Associated Infections (HAIs) Grantee Meeting CDR Oct 19-20 2009.
- Thurston-Enriquez, J.A. , Haas, C.N. , Jacangelo, J. , Riley, K. and Gerba, C.P. 2003. Inactivation of feline calcivirus and adenovirus type 40 by UV radiation, *Appl. Environ. Microbiol.*, 69(1): 577-582.
- Thompson, S.S., Jackson, J.L., Suva-Castillo, M., Yanko, W.A., Jack, Z.E., Kuo, J., Chen, C.L., Williams, F.P. and Schnurr, D.P. 2003. Detection of infectious human adenoviruses in tertiary-treated and ultraviolet-disinfected wastewater, *Wat. Environ. Res.*, 75(2): 163-170.
- Tosa, K. and Hirata, T. 1998. HRWM-39: Photoreactivation of Salmonella following UV disinfection, *IAWQ 19th Biennial International Conference*, Vol. 10, Health- Related Water Microbiology.
- Tosa, K. and Hirata, T. 1999. Photoreactivation of enterohemorrhagic *E. coli* following UV disinfection, *Wat. Res.*, 33(2): 361-366.
- Tree, J.A., Adams, M.R. and Lees, D.N. 1997. Virus inactivation during disinfection of wastewater by chlorination and UV irradiation and the efficacy of F+ bacteriophage as a 'viral indicator', *Wat. Sci. Technol.*, 35(11-12): 227-232.
- Tree, J.A., Adams, M.R. and Lees, D.N. 2005. Disinfection of feline calcivirus (a surrogate for Norovirus) in wastewaters, *J. Appl. Microbiol.*, 98: 155-162.
- Wiedenmann, A. , Fischer, B., Straub, U., Wang, C.-H., Flehmig, B. and Schoenen, D. 1993. Disinfection of Hepatitis A virus and MS-2 coliphage in water by ultraviolet irradiation: Comparison of UV-susceptibility, *Wat. Sci. Tech.*, 27(3-4): 335-338.
- Wiener-Well Y, Galuty M, Rudensky B, Schlesinger Y, Attias D, Yinnon AM. Nursing and physician attire as possible source of nosocomial infections. *American Journal of Infection Control*. 2011 Sep;39(7):555-9.
- Wilson, B.R., Roessler, P.F., Van Dellen, E., Abbaszadegan, M. and Gerba, C.P. 1992. Coliphage MS-2 as a UV water disinfection efficacy test surrogate for bacterial and viral pathogens, *Proceedings, Water Quality Technology Conference*, Nov 15-19, 1992, Toronto, Canada, pp. 219-235, Amer. Wat. Works Assoc., Denver, CO.
- Wu, Y., Clevenger, T. and Deng, B. 2005. Impacts of goethite particles on UV disinfection of drinking water, *Appl. Environ. Microbiol.*, 71(7): 4140-4143.
- Yaun, B.R., Sumner, S.S., Eifert, J.D. and Marcy, J.E. 2003. Response of *Salmonella* and *E. coli* O157:H7 to UV energy, *J. Food Protection*, 66(6): 1071-1073.
- Zimmer, J.L. and Slawson, R.M. 2002. Potential repair of *E. coli* DNA following exposure to UV radiation from both medium- and low-pressure UV sources used in drinking water treatment, *Appl. Environ. Microbiol.*, 68(7): 3293-3299.
- Zimmer, J.L., Slawson, R.M. and Huck, P.M. 2003. Inactivation and potential repair of *C. parvum* following low- and medium-pressure ultraviolet irradiation, *Wat. Res.*, 37(14): 3517-3523.